

October 4, 2017 7:50pm continued hearing for 411 South Road, Cordio, septic replacement, new plan submission DEP # 093-0367

Neil Gorman appeared with a new plan depicting the change to run the pipe to the new leach field through the wetland rather than through a heavily treed upland between 2 wetland areas without trees.

The only vegetation in the wetland to be crossed is jewel weed, which will rebound rapidly from the ditch.

Some changes to the construction notes provided by Neil:

Section 1 - #1 change agent to Commission

#2 expeditious – not to exceed 5 days.

#3 – minimum area necessary n- not to exceed 3 ft in width.

#8 – replace leaf litter with decomposed layer of material.

Section 3

4 preconstruct the sleeve for the forced main

Section 5

#2 – to be inspected by the Cons Comm

Details of these construction notes are now reflected in the plan.

Neil will get the changes to the Commission within the next week.

Motion to closed the hearing and issue an OOC. Cathy 2nd motion. Unanimous in favor of the motion. Cathy will write the OOC.

Hearing closed at 8:17pm