

1/3/2018 8:00 - continued hearing for 2 lots on Fitchburg State Road by Hancock Associates
Breitmeier Owner DEP# 093-370

New plan was submitted to the Commission showing the new location of the two proposed homes on the two lots.

Brian Goudreau.

Every 6 feet (3 contour lines) there will be either jute matting or vegetation installed to hold the slope.

Pressure Treated guard rail within the 100 ft buffer. Must be wetlands safe.

Wattles will have biodegradable netting, be stakes on either side rather than through the middle, and filled with mulch rather than straw.

Wetland markers on wetland bounds and along the tree line.

Driveway permit in hand at the pre-construction site visit.

Motion made and 2nd to close the hearing. Vote unanimous in favor of the motion to close the hearing.

Include grading a shallow swale along the tree line.

Would like to see the verbiage before the OOC is issued. – a day or two before the next meeting.

Closed @8:35pm