

June 6, 9:05pm, Northland Engineers, Lot 4 Main St. DEP# 93-379

Northland Engineers, Angel Lehtonen presenting for Richard Lehtola, current owner.

3 bedroom dwelling.

Driveway and part of the dwelling are inside the 100 ft buffer. Closest area to wetland edge is drilled well is 50 ft.

Driveway grading is 55 from wetlands edge. Corner of house is 48 ft from edge of wetlands.

4ft deep Trench from dug well is 34 ft from the wetland bound.

No fertilizers, herbicide, insecticide in 100 ft buffer

No salts on driveway

No water from house roof into 100 ft buffer.

Roofs must be pitched to either side , but not towards wetland.

No removal of vegetation from 50 ft buffer.

If drill the optional Well drilling 50 ft from the wetland line – need to create a slurry hole and placement of the chlorinated water.

Driveway pitched away from the wetland/

Motion to close the hearing @9:20pm and issue OOC on June 20,2018. Motion passed unanimously.